



Gatto. No.	adatto isolante	Palla IEC codice	Dimensioni (mm)				nominale carico insufficiente kN	Peso kg
			D	d	B	h <sub>1</sub>		
Q-7	XP-7	16mmA.B	17	22	16	50	70	0.3
QP-7	XP-7	16mmA.B	17	20	16	50	70	0.3
QP-10	XP-10	16mmA.B	17	20	16	50	100	0.3
QP-12	XP-12	16 millimetri	17	20	16	50	120	0.3
QP-16	XP-16	20 millimetri	24	26	20	60	160	0.5
QP-21D	XP-21	20 millimetri	21	29	20	70	210	1.0
QP-20	XP-20	24 millimetri	25	30	24	80	200	1.0
QP-30	XP-30	24 millimetri	25	39	30	80	300	1.1

Gatto. No.	adatto isolante	Dimensioni (mm)					nominale carico insufficiente kN	Peso kg
		h <sub>1</sub>	h <sub>2</sub>	R	D	B		
QH-7	XP-7	114	57	11	17	16	70	0.6
QH-12	XP-12	120	63	11	17	16	120	0.7
QH-16	XP-16	130	70	13	26	20	160	1.0
QH-7A	XP-7	90	52	11	17	16	70	0.5